

TR-05662

Powersafe Panel Source T5



Test Date: 07/07/16 Operator: D.Maclachlan

TYPE AND DESCRIPTION OF TEST

POWERSAFE PANEL SOURCE T5. DIRECT RESISTANCE WITH 500A CURRENT.

OBJECTIVE

The object of this test is to assess the current carrying capacity of the Powersafe Panel Source T5 connector.

TEST METHOD

A specified test current shall be applied to the contacts of the specimen for a minimum period of 3 hours or until equilibrium is reached. (Less than 1 degree per hour).
The Powersafe Connectors will be fed with between 500A and 510A from the 3000A load unit via 2 x 1m lengths of HO7RN-F single core 150mm² cable.

REQUIREMENTS

The connectors must be capable of carrying the specified test current for a minimum period of 3 hours without exceeding the specified temperature rise.

TEST ITEMS

- 1x Powersafe S120 Line Drain Connector terminated with 150mm² cable
- 1x Powersafe Panel Source T5 Connector terminated with A30-M12 Lug on 150mm² cable

EQUIPMENT USED

INSTRUMENT	DESCRIPTION	CALIBRATION EXPIRY DATE
Current Generation	T & R PCU1 Mk3 P.C.I.T.S. (21TE0216)	20/01/2017
External Load Unit	3000A Loading Unit	20/01/2017
Digital Thermometer	YF-160A Thermocoupler + 6 Probes	04/02/2017




This report is the property of Phase 3 Connectors Ltd and must not, without their written consent, be passed on, copied or used for any other purpose.

TR-05662

Powersafe Panel Source T5

Test Date: 07/07/16 Operator: D.Maclachlan



TIME	AMBIENT	DRAIN CONTACT	CABLE JACKET	CABLE CORE	CONTACT STUD	SOURCE CONTACT	INSULATOR	AMPS
0.5	18.2	61.3	41.6	59.7	66.4	66.9	40.1	504.0
1	19.6	76.3	50.6	68.8	79.6	77.3	52.8	502.0
1.5	19.7	85.4	56.5	77.5	89.3	88.1	61.6	504.0
2	19.5	87.3	58.1	77.8	91.4	90.2	64.6	502.0
2.5	19.7	90.1	58.7	78.2	91.8	90.7	64.9	505.0
3	19.7	91.0	58.9	78.6	92.0	90.9	64.9	505.0
3.5	19.5	89.9	58.9	78.7	92.4	91.1	64.8	507.0
4	19.1	90.3	58.8	78.7	92.5	91.2	64.7	507.0

TR-05662

Powersafe Panel Source T5



Test Date: 07/07/16 Operator: D.Maclachlan

FINAL RESULTS

PROBE POSITION	TEMPERATURE (C)	T (MEASURED-AMBIENT)	AMPS
Ambient	19.1	N/A	N/A
Line Drain Contact (P1)	90.3	71.2	507A
Cable Jacket (P2)	58.8	39.7	507A
Cable Core (P3)	78.7	59.6	507A
Panel Contact Stud (P4)	92.5	73.4	507A
Panel Source Contact (P5)	91.2	72.1	507A
Panel Source Insulator (P6)	64.7	45.6	507A

CONCLUSION

MEASUREMENT	RESULT
Maximum Allowable Temperature	125°C
Maximum Recorded Temperature Rise @ Insulated Body (above ambient)	45.6°C
Maximum Allowable Temperature of Contacts	125°C
Maximum Recorded Temperature Rise (above ambient)	73.4°C
TEMPERATURE RISE WITHIN BS EN 61984 -2009 AND VDE ALLOWABLE LIMITS.	PASS



This report is the property of Phase 3 Connectors Ltd and must not, without their written consent, be passed on, copied or used for any other purpose.